

COMMON TOXIC GASES AS DEFINED BY THE TOXIC GAS ORDINANCE AND CFC

For Use By All Jurisdictions, Cities and County, Within the Limits of Santa Clara County.

GAS & FORMULA	CAS No./ UN No.	UBC/CFC CLASS ¹	TGO CLASS ²	IDLH ³	LC ₅₀ ⁴	LOC	MAX TQ	PEL ⁵
Ammonia - NH ₃	7664-41-7 UN1005	Corrosive ^{6,7} Flammable	III	300 ppm	4000 ppm	30 ppm	8000 lbs	50 ppm
Arsine - AsH ₃	7784-42-1 UN2188	Highly Toxic Flammable	I	3 ppm	20 ppm	0.3 ppm	N/A	0.05 ppm
Boron Tribromide - BBr ₃	10294-33-4 UN2692	Toxic WR-2	II	50 ppm	380 ppm	5 ppm	760 lbs	1 ppm ©
Boron Trichloride - BCl ₃	10294-34-5 UN1741	Corrosive ⁶ WR-1	II	25 ppm ⁸	2541 ppm	2.5 ppm	5082 lbs	5 ppm
Boron Trifluoride - BF ₃	7637-07-2 UN1008	Toxic WR-1	II	25 ppm	806 ppm	2.5 ppm	1612 lbs	1 ppm ©
Bromine - Br ₂	7726-95-6 UN1744	Highly Toxic Corrosive Oxidizer	I	3 ppm	113 ppm	0.3 ppm	N/A	0.1 ppm
Carbon Monoxide - CO	630-08-0 UN1016	Flammable ⁶	III	1200 ppm	3760 ppm	120 ppm	7520 lbs	50 ppm
Chlorine - Cl ₂	7782-50-5 UN1017	Toxic Corrosive Oxidizer	II	10 ppm	293 ppm	1 ppm	586 lbs	1 ppm ©

- Notes:
1. Class as defined in CFC: 1.) Health Hazards per Article 2; Highly Toxic = < 200 LC₅₀, Toxic = 200 - 2,000 LC₅₀. 2.) Physical Hazards per UFC Standard 79-3.
 2. TGO Class Defined As: Class I = < 200 LC₅₀, Class II = 200 - 3000 LC₅₀, Class III = 3001 - 5000 LC₅₀
 3. IDLH values published in 1994 by the National Institute for Occupational Safety and Health (NIOSH).
 4. LC₅₀ data: Lowest reported value, 1 hour adjusted, taken from DOT, CGA, RTECS.
 5. PEL values published by OSHA (29 CFR, part 1910.1000, Table Z-1) dated 7/1/95. OSHA values used if available, otherwise TLV from ACGIH or Cal OSHA values used. © = Ceiling Limit.
 6. Moderately toxic as adopted by the cities of San Jose, Santa Clara, and Milpitas: LC₅₀ = 2,000 - 5000.
 7. When used as a refrigerant, UBC Class does not apply. See TGO consensus guidelines for additional information regarding ammonia refrigeration systems.
 8. IDLH determined by 0.01 of LC₅₀.
 9. Cal OSHA PEL, Title 8, Section 5155, 9/1/95.
 10. Threshold Limit Values (TLV) from the American Conference of Governmental Industrial Hygienists (1994-1995).

GAS & FORMULA	CAS No./ UN No.	UBC/CFC CLASS ¹	TGO CLASS ²	IDLH ³	LC ₅₀ ⁴	LOC	MAX TQ	PEL ⁵
Chlorine Dioxide - ClO ₂	10049-04-4 NA9191	Toxic UR-3 Oxidizer WR-1	II	5 ppm	250 ppm	0.5 ppm	500 lbs	0.1 ppm
Chlorine Trifluoride - ClF ₃	7790-91-2 UN1749	Toxic Oxidizer WR-3	II	20 ppm	299 ppm	2 ppm	598 lbs	0.1 ppm ©
Diborane - B ₂ H ₆	19278-45-7 UN1911	Highly Toxic Flammable WR-2	I	15 ppm	80 ppm	1.5 ppm	N/A	0.1 ppm
Dichlorosilane - SiH ₂ Cl ₂ (HCl)	4109-96-0 UN2189	Toxic Corrosive Flammable	II	50 ppm	314 ppm	5 ppm	628 lbs	5 ppm ©
Ethylene Oxide - C ₂ H ₄ O	75-21-8 UN1040	Flammable ⁶ UR-3	III	800 ppm	4350 ppm	80 ppm	8700 lbs	1 ppm
Fluorine - F ₂	7782-41-4 UN1045	Highly Toxic Oxidizer	I	25 ppm	185 ppm	2.5 ppm	N/A	0.1 ppm
Germane - GeH ₄	7782-65-2 UN2192	UR-3 Toxic Flammable	II	6 ppm ⁸	622 ppm	0.6 ppm	1244 lbs	0.2 ppm ⁹
Hydrogen Bromide - HBr	10035-10-6 UN1048	Corrosive ⁶	II	30 ppm	2860 ppm	3 ppm	5720 lbs	3 ppm
Hydrogen Chloride - HCl	7647-01-0 UN1050	Corrosive ⁶	II	50 ppm	2810 ppm	5 ppm	5620 lbs	5 ppm ©
Hydrogen Cyanide - HCN	74-90-8 UN1051	Highly Toxic Flammable	I	50 ppm	40 ppm	5 ppm	N/A	10 ppm
Hydrogen Fluoride - HF	7664-39-3 UN1052	Toxic	II	30 ppm	1300 ppm	3 ppm	2600 lbs	3 ppm
Hydrogen Selenide - H ₂ Se	7783-07-5 UN2202	Highly Toxic Flammable	I	1 ppm	2 ppm	0.1 ppm	N/A	0.05 ppm
Hydrogen Sulfide - H ₂ S	7783-06-4 UN1053	Toxic Flammable	II	100 ppm	712 ppm	10 ppm	1424 lbs	20 ppm
Methyl Bromide - CH ₃ Br	74-83-9 UN1062	Toxic Flammable	II	250 ppm	1007 ppm	25 ppm	2014 lbs	20 ppm ©

GAS & FORMULA	CAS No./ UN No.	UBC/CFC CLASS ¹	TGO CLASS ²	IDLH ³	LC ₅₀ ⁴	LOC	MAX TQ	PEL ⁵
Methylisocyanate - CH ₃ NCO	624-83-9 UN2480	Highly Toxic Flammable WR-2	I	3 ppm	22 ppm	0.3 ppm	N/A	0.02 ppm
Methyl Mercaptan - CH ₃ SH	74-93-1 UN1064	Toxic Flammable	II	150 ppm	1350 ppm	15 ppm	2700 lbs	10 ppm ©
Nickel Carbonyl - Ni(CO) ₄	13463-39-3 UN1259	Highly Tox. UR-3 Flammable WR-1	I	2 ppm	18 ppm	0.2 ppm	N/A	0.001 ppm
Nitric Oxide - NO	10102-43-9 UN1660	Highly Toxic Oxidizer	I	100 ppm	115 ppm	10 ppm	N/A	25 ppm
Nitrogen Dioxide - NO ₂	10102-44-0 UN1067	Highly Toxic Oxidizer WR-1	I	20 ppm	115 ppm	2 ppm	N/A	5 ppm ©
Phosgene - COCl ₂	75-44-5 UN1076	Highly Toxic WR-1	I	2 ppm	5 ppm	0.2 ppm	N/A	0.1 ppm
Phosphine - PH ₃	7803-51-2 UN2199	Highly Toxic Pyrophoric	I	50 ppm	20 ppm	5 ppm	N/A	0.3 ppm
Phosphorus Oxychloride - POCl ₃	10025-87-3 UN1810	Highly Toxic WR-2	I	0.96 ppm ⁸	96 ppm	0.096 ppm	N/A	0.1 ppm ^{8,9}
Phosphorus Pentafluoride - PF ₅	7647-19-0 UN2198	Toxic Oxidizer WR-1	II	2.6 ppm ⁸	260 ppm	0.26 ppm	520 lbs	3 ppm
Phosphorus Trichloride - PCl ₃	7719-12-2 UN1809	Toxic UR-2 WR-2 Oxidizer	II	25 ppm	208 ppm	2.5 ppm	416 lbs	0.5 ppm
Selenium Hexafluoride - SeF ₆	7783-79-1 UN2194	Highly Toxic	I	2 ppm	50 ppm	0.2 ppm	N/A	0.05 ppm (as Se)
Silicon Tetrachloride - SiCl ₄ (HCl)	10026-04-7 UN1818	Toxic Corrosive	II	50 ppm	750 ppm	5 ppm	1500 lbs	5 ppm ©
Silicon Tetrafluoride - SiF ₄ (HF)	7783-61-1 UN1859	Toxic WR-2	II	30 ppm	450 ppm	3 ppm	900 lbs	0.1 ppm
Stibine - SbH ₃	7803-52-3 UN2676	Highly Toxic Flammable	I	5 ppm	20 ppm	0.5 ppm	N/A	0.1 ppm
Sulfur Dioxide - SO ₂	7446-09-5 UN1079	Corrosive ⁶	II	100 ppm	2520 ppm	10 ppm	5040 lbs	5 ppm

GAS & FORMULA	CAS No./ UN No.	UBC/CFC CLASS ¹	TGO CLASS ²	IDLH ³	LC ₅₀ ⁴	LOC	MAX TQ	PEL ⁵
Sulfuryl Fluoride - SO ₂ F ₂	2699-79-8 UN2191	Corrosive ⁶	III	200 ppm	3020 ppm	20 ppm	6040 lbs	5 ppm
Tellurium Hexafluoride - TeF ₆	7783-80-4 UN2195	Highly Toxic	I	1 ppm	25 ppm	0.1 ppm	N/A	0.02 ppm (as Te)
Titanium Tetrachloride - TiCl ₄	7550-45-0 UN1838	Highly Toxic Corrosive WR-2	I	1.3 ppm	119 ppm	0.13 ppm	N/A	
Tungsten Hexafluoride - WF ₆ (HF)	7783-82-6 UN2196	Toxic Corrosive WR-2	II	30 ppm	217 ppm	3 ppm	434 lbs	0.1 ppm

Notes: 1. Class as defined in CFC: 1.) Health Hazards per Article 2; Highly Toxic = < 200 LC₅₀, Toxic = 200 - 2,000 LC₅₀. 2.) Physical Hazards per UFC Standard 79-3.

2. TGO Class Defined As: Class I = < 200 LC₅₀, Class II = 200 - 3000 LC₅₀, Class III = 3001 - 5000 LC₅₀

3. IDLH values published in 1994 by the National Institute for Occupational Safety and Health (NIOSH).

4. LC₅₀ data: Lowest reported value, 1 hour adjusted, taken from DOT, CGA, RTECS.

5. PEL values published by OSHA (29 CFR, part 1910.1000, Table Z-1) dated 7/1/95. OSHA values used if available, otherwise TLV from ACGIH or Cal OSHA values used. © = Ceiling Limit.

6. Moderately toxic as adopted by the cities of San Jose, Santa Clara, and Milpitas: LC₅₀ = 2,000 - 5000.

7. When used as a refrigerant, UBC Class does not apply. See TGO consensus guidelines for additional information regarding ammonia refrigeration systems.

8. IDLH determined by 0.01 of LC₅₀.

9. Cal OSHA PEL, Title 8, Section 5155, 9/1/95.

10. Threshold Limit Values (TLV) from the American Conference of Governmental Industrial Hygienists (1994-1995).